BOREWELL COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 116 Date : 16-03-17

1. Customer's Name and Address : AEE YELAHANKA
   with Telephone No.
2. Well Location : 4th Cross 3rd main MARUTHINAGAR
3. Total Well Depth / Drilled in Ft. : 900 Ft
4. Casing Erected in Ft. : 170 - 190 Ft
5. Water Struck at the Depth of : 600 - 740 Ft
6. Total Yield (Measuring method "V" Norch : 2" / Inches on "V" Norch)
7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Rock Soil.
8. At the Depth of : 960 Ft
9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

Manager / Proprietor

SRI BAALAMURUGAN BOREWELLS

Hennur-Bagalur Road, opp. Vijaya Bank, Kothanur, Bangalore
Mob.: 9845020536, 9901920004

WORK REPORT

To
AEE YELAHANKA
TANK BUND ROAD
VENKTALA

No. : 140

Date : 16/04/17

S.No.	Particulars	Rft	Water Yeild	Remarks
1.	Size of the Borewell	6 1/2		
2.	Total Deapth of the Borewell	1200		
3.	MS Casing Erected	178		
4.	1st Water Source at the Deapth	785	1/2"	
5.	2nd Water Source at the Deapth	940	1/2"	
6.	3rd Water Source at the Deapth	1020	1/2"	
7.	4th Water Source at the Deapth			
8.	If any Silt, Boulders at the Deapth	- No -	-	
9.	Nature of Water	Sweet		
10.	Motor Pump to be used	Yes	-	
11.	Any other Remarks	-	-	
12.	Total Yeild of the Borewell	1140	1 1/2	

Thanking You

Yours Faithfully
For Sri Baalamurugan Borewells

SRI BAALAMURUGAN BOREWELLS

Hennur-Bagalur Road, opp. Vijaya Bank, Kothanur, Bangalore
Mob. : 9845020536, 9901920004

WORK REPORT

To
AEE YELAHANKA
JAYAMUNI Nagar
NITTE College Road

No. : 147

Date : 20/03/17

S.No.	Particulars	Rft	Water Yeild	Remarks
1.	Size of the Borewell	6½		
2.	Total Deapth of the Borewell	1100		
3.	MS Casing Erected	145		
4.	1st Water Source at the Deapth	735	1"	
5.	2nd Water Source at the Deapth	855	½"	
6.	3rd Water Source at the Deapth	975	½"	
7.	4th Water Source at the Deapth	—	-	
8.	If any Silt, Boulders at the Deapth	- No -	- No -	
9.	Nature of Water	Sweet	-	
10.	Motor Pump to be used	Yes	-	
11.	Any other Remarks	—	-	
12.	Total Yeild of the Borewell	1120	2"	

Thanking You

Yours faithfully
For Sri Baalamurugan Borewells

Water Diviner

ಸಮೃದ್ಧಿ

॥ ಶ್ರೀ ಗಂಗಮ್ಮ ಕೃಪಾ ॥

Smt. Kavitha Singh
Mob : 9964702826

Samrudhi Ground Water Consultant

46, Gangamma Temple Street, Near Gangamma Temple, Malleshwaram, Bangalore-03.

Ref. :.....

Date : 04/04/12

REPORT ON GROUND WATER INVESTIGATION

Name AEE BBMP

Address 2nd main 4th Cross Venkatala

Location Near Masjid Road

Topography

Soil Type Loose Soil

Rock Type White Rock

Nos.

RECOMMENDATIONS

Depth 1100 - 1300

Casing 180 - 200

Yield 2"

Aquifers 2½

Remarks Shilted type

Note : The Survey was carried out by this divining / Geophysical method of Surveying is with our good knowledge and experience, However no guarantee of water will be given

ನೀರು ಅತ್ಯಮೂಲ್ಯ, ಅದನ್ನು ಸಂರಕ್ಷಿಸಿ... Water is precious, Conserve it... ಗಿಡ ಬೆಳೆಸಿ, ಮರಗಳನ್ನು ಉಳಿಸಿ

Smt. Kavitha Singh

Water Diviner

ಸಮೃದ್ಧಿ

॥ ಶ್ರೀ ಗಂಗಮ್ಮ ಕೃಪಾ ॥

Smt. Kavitha Singh
Mob : 9964702826

Samrudhi Ground Water Consultant

46, Gangamma Temple Street, Near Gangamma Temple, Malleshwaram, Bangalore-03.

Ref. :.....

Date : 04/04/2020

REPORT ON GROUND WATER INVESTIGATION

Name — AEE BBMP

Address — Jayamuni Nagara 1st Main Road NITTE College Road Venkata

Location — Near Eswar's house

Topography —

Soil Type — Hard soil

Rock Type — Black Rock.

Nos.

RECOMMENDATIONS

Depth — 1100 - 1200

Casing — 150 - 170

Yield — 2½'

Aquifers — 2½'

Remarks — –

Note : The Survey was carried out by this divining / Geophysical method of Surveying is with our good knowledge and experience, However no guarantee of water will be given

ನೀರು ಅತ್ಯಮೂಲ್ಯ, ಅದನ್ನು ಸಂರಕ್ಷಿಸಿ... Water is precious, Conserve it... ಗಿಡ ಬೆಳೆಸಿ, ಮರಗಳನ್ನು ಉಳಿಸಿ

Smt. Kavitha Singh

Kavitha S

Water Diviner

ಸಮೃದ್ಧಿ

॥ ಶ್ರೀ ಗಂಗಮ್ಮ ಕೃಪಾ ॥

Smt. Kavitha Singh
Mob : 9964702826

Samrudhi Ground Water Consultant

46, Gangamma Temple Street, Near Gangamma Temple, Malleshwaram, Bangalore-03.

Ref. :.....

Date : 04/04/12

REPORT ON GROUND WATER INVESTIGATION

Name AEE BBMP

Address 3rd Main · Maruthinagar.
Yelahanka.

Location Near Bhuvaneshwari Yuvakara Sangha

Topography —

Soil Type Hard soil

Rock Type Black And White

Nos.

RECOMMENDATIONS

Depth 1100 - 1200

Casing 150 - 170

Yield 2½"

Aquifers 3"

Remarks —

Note : The Survey was carried out by this divining / Geophysical method of Surveying is with our good knowledge and experience, However no guarantee of water will be given

ನೀರು ಅತ್ಯಮೂಲ್ಯ, ಅದನ್ನು ಸಂರಕ್ಷಿಸಿ... Water is precious, Conserve it... ಗಿಡ ಬೆಳೆಸಿ, ಮರಗಳನ್ನು ಉಳಿಸಿ

Smt. Kavitha Singh
Kavitha.S.

Water Diviner